

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
27830	Complete	10/14/2011		Office	GATEWAY BUILDING
	My office is reasonably comfortable ... I am fiddling with the thermostat multiple times a day to keep it comfortable, but it does seem to be working ok. Heat gain (and probably loss) through all the glass and sun continues to be a problem - but reasonably manageable. Thanks for your work!	10/20/2011	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	402E
	Our file room 402G is too warm - runs 76-78 and the "coffee" room is extraordinarily warm. There is no thermostat in the coffee room and I suspect it may run off the same thermostat as G. Since the doors to the coffee room are always shut the temp really shoots up - the filling the Oreos is always really soft - but then that is a good thing!				
	Certainly not a big urgency to this issue, but wanted to see if you can flip a switch and improve the situation.				
	Thank you for all your work.				
28152	Complete	11/10/2011	Beth Luers	Office	GATEWAY BUILDING
	In GW Rooms 412, 412A and 412B: In our offices the temperature is always cold. Joanna and Bill have pushed the warmer button on their thermostat for their offices and it doesn't work. Stays cold. Robert stopped by on 11/9/11 and looked at the situation.	11/15/2011	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	412
	If you have any questions, please contact Joanna Anderson 2210, Bill Landen 2667 or Beth Luers 2201.				
28388	Complete	11/29/2011		Boiler Room	GATEWAY BUILDING
	AIR HANDLER SHUT DOWN. CALLED ELOGIC TO MEET TO CHECK ALARM - ROBERT TAYLOR	12/5/2011	TAYLOR, ROBERT	Heating/Ventilation /Air Conditioning	000
	ROBERT/ELOGIC ADJUSTED END SWITCHES SLIGHTLY AND RESET UNIT, ALSO NOTICED DAMPER SEALS NOT REPLACED YET 11/25/11	Medium			
28923	Complete	1/11/2012		Classroom	GATEWAY BUILDING
	ROOM PRESSURE IS OFF KILTER, VERY NOISY IN ROOM DUCT - JOHN CRAIGMILE WARRANTY - AP WO#6139	1/12/2012	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	208
		Medium			

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
29122	Void	1/25/2012	Beth Luers	Office	GATEWAY BUILDING
	In GW 349A- Shari Greiner office: Would like to have the thermostat moved in her office. It is currently behind the hutch on my desk and Shari believe that it always goes to an unoccupied mode because it can't sense that Shari is in the room.	10/1/2012	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	100
	Any questions, please contact Shari Greiner #2049	Medium			
29502	Complete	2/24/2012		Roof	GATEWAY BUILDING
	EXHAUST FAN MAKING NOISE, BELT NEEDS REPLACEMENT (WARRANTY - BELT#AX26) COVER IS MISSING - JOHN CRAIGMILE	2/25/2012	JOHNSON, ROBIN	Heating/Ventilation /Air Conditioning	000
		Medium			
29702	Complete	3/20/2012		Roof	GATEWAY BUILDING
	BROKEN MOTOR MOUNTS ON FANS - JOHN CRAIGMILE	3/28/2012	JOHNSON, ROBIN	Heating/Ventilation /Air Conditioning	000
		Medium			
30283	Complete	4/30/2012	SHANNON ESKAM	Classroom	GATEWAY BUILDING
	Problem with being able to adjust heat in GW 218. Room got hot and instructor was unable to get the heat turned down.	5/1/2012	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	218
		Medium			
30366	Complete	5/3/2012	SHANNON ESKAM	Room	GATEWAY BUILDING
	Ceiling tiles have not been reinstalled in hallway/front area of GW408. Could we please get someone to come and put them back in.	6/5/2012 5:49:57	SANCHEZ, ALLEN	Heating/Ventilation /Air Conditioning	408
		Medium			
30587	Complete	5/16/2012	GALE LARA	3rd Floor	GATEWAY BUILDING
	Please change the range on the thermostat in the Board Room, GW 312. It is cold in that room, and the highest the range is 70 degrees. So, we would like to set the range higher than 70 degrees. Thank you.	6/5/2012	CRAIGMILE, JOHN	Heating/Ventilation /Air Conditioning	307
		Medium			

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
30877	Complete	6/5/2012		Stairway	GATEWAY BUILDING
	HEATERS IN GW WEST SIDE EXIT STAIRWAY ARE NOT WORKING CORRECTLY, 1ST FLOOR FAN WILL NOT SHUT DOWN WITH CONTROL, UPSTAIRS NOT WORKING CORRECTLY - JOHN CRAIGMILE (WARRANTY)	7/18/2012	TEMP, SUBCONTRACTOR		ALL
		Medium		Heating/Ventilation /Air Conditioning	
31460	Complete	7/13/2012	Becky Smith	3rd Floor	GATEWAY BUILDING
	Could you please come and change the setpoint on Sarah Tooker's thermostat to be 70 degrees? The higher setpoint that Margo had is making her ill.	10/1/2012	CRAIGMILE, JOHN		303C
		Medium		Heating/Ventilation /Air Conditioning	
31497	Complete	7/19/2012		Roof	GATEWAY BUILDING
	A/C PIPE RUBBING ON SHEET METAL INNOVENT UNIT - WARRANTY - JOHN CRAIGMILE	7/20/2012	CRAIGMILE, JOHN		000
		Medium		Heating/Ventilation /Air Conditioning	
32193	Complete	8/29/2012		Boiler Room	GATEWAY BUILDING
	GW AHU: COMPRESSOR LOUD AND ROUGH SOUNDING, WOULD LIKE THE SHEET METAL SPECIALIST TO TAKE ANOTHER LOOK - TAYLOR	10/22/2012	TAYLOR, ROBERT		
		Medium		Heating/Ventilation /Air Conditioning	
33526	Complete	12/6/2012		Boiler Room	GATEWAY BUILDING
	BOILER IS HAVING ISSUES, THIS IS WARRANTY - JOHN CRAIGMILE	2/27/2013	TAYLOR, ROBERT		000
		Medium		Heating/Ventilation /Air Conditioning	
34256	Complete	1/30/2013		Office	GATEWAY BUILDING
	The air vents behind the front counter in Enrollment Services seem to blow cold air all the time on the staff working the front counter. The staff have taken to wearing coats or heavy sweatshirts to try to stay warm. If the air flow could be re-directed or some blocked off, or something to make it more comfortable it would be greatly appreciated. Darry	2/1/2013	TAYLOR, ROBERT		350
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
34627	Complete	3/3/2013 12:17:44	JOHN CRAIGMILE		GATEWAY BUILDING
	Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details.	3/20/2013 1:13:54	GOLTERMANN, BRYAN		
	Completed maintenance task.	Medium		Heating/Ventilation /Air Conditioning	GW 1
35046	Complete	4/8/2013		Office	GATEWAY BUILDING
	ATTACH AIR DEFLECTOR TO AIR VENT - ROBERT TAYLOR	4/17/2013	TAYLOR, ROBERT		303E
		Medium		Heating/Ventilation /Air Conditioning	
35120	Complete	4/15/2013		Roof	GATEWAY BUILDING
	EXTEND CURB ON FRESH AIR HOOD ON ROOF TO STOP SNOW FROM ENTERING BLDG. CURB WAS INSTALLED TO LOW - TOM P	4/26/2013	Popilek, Thomas		000
		Medium		Heating/Ventilation /Air Conditioning	
35228	Complete	4/26/2013		Room	GATEWAY BUILDING
	PLEASE GIVE THEM THE ABILITY TO CONTROL THEIR AIR CONDITIONING, ON OFF, AND DEGREES - CAROL - THANK YOU	4/26/2013	Popilek, Thomas		403B
		Medium		Heating/Ventilation /Air Conditioning	
36684	Complete	7/19/2013		Mechanical Room	GATEWAY BUILDING
	AHU PRESSURE SWITCH NEEDS REPLACED ON COMPRESSOR 1 - ROBERT TAYLOR	8/21/2013	TAYLOR, ROBERT		000
		Medium		Heating/Ventilation /Air Conditioning	
37057	Complete	8/8/2013		Mechanical Room	GATEWAY BUILDING
	LEAK ON BOILER 3 VENT - RODNEY OSTER	4/28/2014 2:13:02	Popilek, Thomas		000
		Medium		Heating/Ventilation /Air Conditioning	
37277	Complete	8/27/2013		Office	GATEWAY BUILDING
	SMOKE DUCT TROUBLE ON FIRE ALARM PANEL, 3RD FLOOR NW OFFICE - OSTER	4/28/2014 2:13:09	Popilek, Thomas		
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
37280	Complete	8/27/2013	Beth Luers	Office	GATEWAY BUILDING
	This has already been taken care. Needed to do a work order.	8/23/2013	Popilek, Thomas	Heating/Ventilation /Air Conditioning	412
	GW 412 & GW 412B in Gateway. The heat in these two offices keep going up. It usually stayed at 71-72 and now goes up to 77 or 78 by 4:30-5. Kim Byrd was wondering if someone could check the heat in these two offices. Kim mentions something about the thermostats.	Medium			
	Any questions, please contact Beth Luers #2201.				
37301	Complete	8/27/2013	KAREL MATHISEN		GATEWAY BUILDING
	Please check and fix HVAC in Rich Fujita's office (GW403A) -- temperature keeps rising throughout the day, starts at about 75 (setpoint at 71), currently at 81 degrees. Thank you.	8/27/2013	Popilek, Thomas	Heating/Ventilation /Air Conditioning	403A
	K. Mathisen (x. 2456) for R. Fujita.	Medium			
37350	Complete	9/1/2013 12:17:12	JOHN CRAIGMILE		GATEWAY BUILDING
	Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details. completed maintenance task.	10/15/2013	GOLTERMANN, BRYAN	Heating/Ventilation /Air Conditioning	GW 1
		Medium			
37471	Complete	9/6/2013		Building	GATEWAY BUILDING
	AHU 3 & 4 - SHEET METAL SPECIALTIES TO CHECK COMPRESSORS - ROBERT TAYLOR	9/18/2013	TAYLOR, ROBERT	Heating/Ventilation /Air Conditioning	000
		Medium			
38581	Complete	12/2/2013	Jan Dalgamo	3rd Floor	GATEWAY BUILDING
	Could you please set the thermostat in GW 307 so that it will go up 2 more degrees? It currently says that it goes up to 74 degrees, but when pushed to 74 degrees it never will register that it gets to that temperature, or close.	12/11/2013	TAYLOR, ROBERT	Heating/Ventilation /Air Conditioning	307
	With an outside door so close to the office door, it tends to stay cool in the office. Thank you, Jan	Medium			

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
39046	Complete In GW 408E (Sarah Olsons' office) the air vent is blowing hot and cold air and makes a significant amount of noise. Could someone please come look at it? Contact: Shannon @x3401	1/7/2014 1/23/2014 Medium	SHANNON ESKAM Popilek, Thomas	4th Floor Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 408E
39726	Complete AHU - ORDER 2 SPARE COMPRESSORS 1 EACH TO HAVE ON HAND - ROBERT TAYLOR DON'T KNOW WHERE THIS STANDS - W/O WAS TURNED IN WITH THIS LIST. 11/18/14. Waiting for approval to purchase equipment.	2/18/2014 7/8/2015 10:29:41 Medium	Taylor, Robert	Boiler Room Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 000
39914	Complete Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details. completed maintenance task.	3/2/2014 12:16:50 3/6/2014 7:28:46 Medium	JOHN CRAIGMILE GOLTERMANN, BRYAN	Heating/Ventilation /Air Conditioning	GATEWAY BUILDING GW 1
40313	Complete May have a bad control module. Doug to look at to possibly have replaced.	4/1/2014 8/12/2014 Medium	ROBERT TAYLOR Taylor, Robert	4th Floor Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 415
41896	Complete Thermostat in 303c is not working. Overall temp in AFM area is high.	7/7/2014 7/7/2014 Medium	Becky Smith Popilek, Thomas	3rd Floor Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 303
41933	Complete Replace control module.	7/11/2014 7/15/2014 Medium	ROBERT TAYLOR TAYLOR, ROBERT	3rd Floor Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 303c
42341	Complete PUT EXHAUST FAN FOR NEW LASER CUTTER FOR JASON EGGEMEYER IN GW 116. BY JASON EGGEMEYER. OK PER M SAWYER. ONGOING 11/18/14	8/5/2014 1/26/2015 Medium	Popilek, Thomas	Office Heating/Ventilation /Air Conditioning	GATEWAY BUILDING GW 116

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
42661	Complete Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details. Completed maintenance task.	8/31/2014 9/2/2014 3:18:17	JOHN CRAIGMILE GOLTERMANN, BRYAN	Heating/Ventilation /Air Conditioning	GATEWAY BUILDING GW 1
43111	Complete RATTLING NOISE COMING FROM HVAC (ROBERT NOTIFIED) - BETH LUERS	9/30/2014 11/18/2014	TAYLOR, ROBERT	Office Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 412
43622	Complete AHU-1 BAS UPGRADE - MIKE SAWYER	11/19/2014 11/19/2014	Sawyer, Mike	Building Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 0
43862	Complete Sheetmetal to repair dampers.	12/9/2014 12/22/2014	ROBERT TAYLOR TAYLOR, ROBERT	Roof Heating/Ventilation /Air Conditioning	GATEWAY BUILDING RTU
44886	Complete Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details. completed maintenance task.	3/1/2015 12:26:53 5/5/2015 8:17:21	JOHN CRAIGMILE GOLTERMANN, BRYAN	Heating/Ventilation /Air Conditioning	GATEWAY BUILDING GW 1
45813	Complete HELPED BRIAN GOLTERMANN REMOVE AND INSTALL FILTERS IN AIR HANDLER - DEAN NEAL	5/4/2015 5/5/2015 7:55:48	Neal, Dean	Mechanical Room Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 000
48036	Complete Monthly - PM Schedule created on 12/20/2012 - Refer to PM schedule details. Brain completed work order	9/6/2015 12:25:28 10/1/2015	JOHN CRAIGMILE KAEHN, RON	Heating/Ventilation /Air Conditioning	GATEWAY BUILDING GW 1
48195	Complete AHU FLOOR COMPRESSOR REPAIR/MAINTENANCE - TOM POPILEK	9/16/2015 9/17/2015 8:20:37	Popilek, Thomas	Mechanical Room Heating/Ventilation /Air Conditioning	GATEWAY BUILDING 300

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
48237	Complete	9/18/2015	Robert Taylor	Boiler Room	GATEWAY BUILDING
	Replace pump seal.	10/1/2015 5:06:44	Taylor, Robert		110
	Done by Clint	Medium		Heating/Ventilation /Air Conditioning	
48344	Complete	9/29/2015	Robert Taylor	Boiler Room	GATEWAY BUILDING
	Replace bleeder valve on water system.	10/7/2015	Taylor, Robert		
	Done by Clint	Medium		Heating/Ventilation /Air Conditioning	
48928	Declined	11/10/2015	Megan Schafer	4th Floor	GATEWAY BUILDING
	I am requesting a space heater for both 412A and 412. Our thermostat only goes up to 74 degrees but it's not that warm in the offices. We're ccccccold!	Medium		Heating/Ventilation /Air Conditioning	412
	We can't put space heater in offices due to safety issues. We reset the heat and increased the set points				
48962	Complete	11/12/2015	RACHEL WRIGHT	Office	GATEWAY BUILDING
	Please check Jon Blesi's heat/cooling system. It is making loud noises. GW116F. Thank you.	11/19/2015	Taylor, Robert		116F
	Adjusted air flow. Visited with Jon about problem.	Medium		Heating/Ventilation /Air Conditioning	
48973	Complete	11/13/2015		Office	GATEWAY BUILDING
	PLEASE CHANGE HEAT SET POINTS TO 72 -76 - VALERIE SAILER	11/16/2015	Taylor, Robert		413
		Medium		Heating/Ventilation /Air Conditioning	
49020	Complete	11/17/2015	Becky Smith	3rd Floor	GATEWAY BUILDING
	It's very, very cold in here. 7 out 8 are wearing coats.	11/17/2015	Taylor, Robert		ALL OF 302 & 303 AREA
	Raised temp on AHU	Medium		Heating/Ventilation /Air Conditioning	
49252	Complete	12/4/2015	Kyla Foltz	3rd Floor	GATEWAY BUILDING
	Please visit with Paula Epperson, Daniel Dike & Mala Stagg about the ventilation behind the ES Counter. It blows cold air on them, and they are cold most days! Please make adjustments. Last year, they made adjustments and it helped a lot. This year, they are cold. Thanks, Kyla	1/19/2016 9:33:11	Taylor, Robert		350
	Clint-2hrs	Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
49673	Void	1/11/2016	Patti Rohrbeck	4th Floor	GATEWAY BUILDING
	The heat does not seem to be working properly in 402C, 402D or 402G. It is very cold	Medium		Heating/Ventilation /Air Conditioning	402
49835	Complete	1/21/2016	Megan Schafer	4th Floor	GATEWAY BUILDING
	I have made this request previously but it has not been fixed. I need the thermostat adjusted so I can turn it up to 78. Currently, I can only turn it up to 74 which only gets the heat to 72 is what the thermostat reads and I'm FREEZING! Thanks!!! 78 is what you are getting now, Enjoy	1/21/2016 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	GW412
50219	Complete	2/19/2016	Robert Taylor	Concession Stand	GATEWAY BUILDING
	Commercial Refrigeration to fix cooler.	2/22/2016 4:57:16 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	
50284	Complete	2/24/2016		Room	GATEWAY BUILDING
	INSTALL RANGE HOOD - TOM POPILEK	3/21/2016 9:07:27 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	222
	Clint,Ron,Dean 6HRS.				
51635	Complete	6/17/2016	Carley Thompson (Stenson)	4th Floor	GATEWAY BUILDING
	Please contact Laura Driscoll regarding putting in a directional vent in her office to help prevent cold air from hitting her at her work desk x2733. Blocked off vent.	7/1/2016 6:29:50 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	408F
51692	Complete	6/23/2016	Robert Taylor	Roof	GATEWAY BUILDING
	Replace condenser fan motor and order spare.	8/8/2016 4:33:42 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	
51905	Complete	7/15/2016	Thomas Popilek	Roof	GATEWAY BUILDING
	Replace sheetmetal panels in rooftop unit. To be done August 6-7.	8/6/2016 High	Popilek, Thomas	Heating/Ventilation /Air Conditioning	
51936	Complete	7/19/2016		Roof	GATEWAY BUILDING
	REPLACE COMPRESSORS FOR ROOF TOP UNIT - TOM POPILEK	7/25/2016 4:41:16 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	000

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
51939	Void	7/19/2016	Rebekah Wise	3rd Floor	GATEWAY BUILDING
	Foundation office GW room 306 and sub-offices are registering over 80' each day. The AC unit doesn't seem to be blowing cool air. surrounding offices appear to be cooling. Can someone come evaluate the situation? Contact Becky Wise @2256 Thank you. Becky - I sent you an email explaining	Medium		Heating/Ventilation /Air Conditioning	306
52116	Complete	8/8/2016	Megan Schafer	3rd Floor	GATEWAY BUILDING
	It is FREEZING!!! in Enrollment Services. In hopes that there can be some resolution the following is the request from those offices. Please make thermostats have an 8 degree range as follows: GW339 70-78, GW341 66-74, GW342 70-78, GW344 70-78, GW350 thermostat by GW348 (Student Success Lobby area) 66-74, thermostat at GW350A is locked? please change range to 72 to 80 and change heating point to 74 and cooling point to 78, thermostat on east wall of GW350 please make the same changes as the thermostat at GW350A, AND PLEASE change the thermostat in GW350 that is by GW348 - this one could be the main problem - it's set at 63 -that's just cold! and the range is 61-65 currently. Please change the range on this thermostat to 68 - 76. If it needs to be set for one temp please set it to 73. I know there are a lot of challenges with all the space and the windows of this building to get the temperature comfortable but I also know that many of the employees on the third floor are freezing in the winter AND the SUMMER. I also know that the thermostats don't seem to be too accurate. I have my thermostat set to 78 and it reads the temp in my office is 75. Thanks for all your help!!!	8/8/2016 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	350
52383	Complete	8/24/2016		Roof	GATEWAY BUILDING
	RE-DO THE INSIDE OF UNIT DUE TO BAD WORKMANSHIP FROM THE CONTRACTORS - TPOPELIK	8/24/2016 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	000
53006	Complete	10/12/2016	Debbie Przybylowicz		GATEWAY BUILDING
	Would like my set point higher on my thermostat so my office isn't so cold. The highest my temp will get to is 72.	10/12/2016 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	311

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
53078	Complete	10/19/2016	Catherine (Tori) Misak	3rd Floor	GATEWAY BUILDING
	It's roasty toasty. Please turn me down to 72 (349B)	10/19/2016	Taylor, Robert		349B and 349
	Please turn 349 up to 73. Done TP	Medium		Heating/Ventilation /Air Conditioning	
53486	Complete	11/30/2016	Megan Schafer	4th Floor	GATEWAY BUILDING
	I'm coooooold! Could you please reset the thermostat in GW415 to a range of 72 to 80. Don't reset the thermostat in Lynnde's office, GW415AOR her meeting room, GW415B. DONE TP	11/30/2016		Heating/Ventilation /Air Conditioning	415
53599	Complete	12/8/2016	Becky Smith	3rd Floor	GATEWAY BUILDING
	Could you please change the setpoint on Matt's thermostat to 70 degrees. He's chilly. Thanks. Done TP	12/9/2016	TEMP, SUBCONTRACTOR		303c
		Medium		Heating/Ventilation /Air Conditioning	
53794	Complete	1/4/2017	Patti Rohrbeck	4th Floor	GATEWAY BUILDING
	The temperature in my office increases as the day goes on as high as 76 degrees. I would like my set point to be 70 and also be able to manually adjust the temperature. This room is set at 68, the ONLY air handler puts in the air I can't stop it!!!	1/4/2017	Taylor, Robert		402
		Medium		Heating/Ventilation /Air Conditioning	
53964	Complete	1/18/2017	RACHEL WRIGHT	Office	GATEWAY BUILDING
	Can the heat in GW116E please be checked? The heat never gets above 67 or 68 degrees, and most mornings in is at 62/63 degrees in this office. Thank you.	1/18/2017		Heating/Ventilation /Air Conditioning	116F
		Medium			
54150	Complete	2/1/2017	Megan Schafer	3rd Floor	GATEWAY BUILDING
	Please adjust the thermostat range in 309, 309A, & 309B to 72-80	2/1/2017			309
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
54303	Complete	2/15/2017	Dana Boe	3rd Floor	GATEWAY BUILDING
	Please reset the heating to the lower temperatures or original settings if possible. I apologize for the updated request but I did not understand what the gentleman was explaining the first time. Office 309B should be set at 66, 309A and 309 set to max of 74. Thank you so much for fixing my mistake. I do apologize again. If you have any questions or just want to scold me, I can be reached at 2015. Dana Boe	2/15/2017 1:29:49	Taylor, Robert	Heating/Ventilation /Air Conditioning	309
54370	Complete	2/23/2017		Building	GATEWAY BUILDING
	MM 2017 - REPAIR AND INVESTIGATE POSSIBLE CAUSES OF AIR HANDLING UNIT MALFUNCTIONS - MSAWYER	11/21/2017	Popilek, Thomas	Heating/Ventilation /Air Conditioning	000
	Investigated found problem, litigation underway.TP	Medium			
54587	Void	3/20/2017		Outside Covered Area	GATEWAY BUILDING
	MM 2017 - PROJECT - INSTALL NEW HVAC UNIT FOR ENTIRE BUILDING - MSAWYER		Sawyer, Mike	Heating/Ventilation /Air Conditioning	000
		Medium			
55079	Complete	5/2/2017	Rebekah Wise	3rd Floor	GATEWAY BUILDING
	Please help! Ann Dalton's office, GW room 306A, is sooooo COLD. I cant get the thermostat to go above 61' and I'm afraid I'll come in some morning to see an "Ann Popsicle" in her chair. She is wearing a winter coat, finger mittens, a scarf, boots, extra socks and a blanket (I just lied about the winter gear). In all seriousness, can someone tell us what we are doing wrong?	5/3/2017	Taylor, Robert	Heating/Ventilation /Air Conditioning	306A
		Medium			
55408	Complete	6/5/2017		Room	GATEWAY BUILDING
	Please set the range of the thermostat in GW 414 between 68 and 74 degrees Fahrenheit.	6/5/2017		Heating/Ventilation /Air Conditioning	414
	Thanks, Belle TP	Medium			

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
55456	Complete	6/9/2017		Office	GATEWAY BUILDING
	Hello Lynn,	6/9/2017	Taylor, Robert		345
	I was wanting to get the temperature adjusted in my office, and was told you could help. I am in office 345 which is on the third floor of the Gateway building. I run warm so could I get the temp range set to like 66 or 67 to 70?	Medium		Heating/Ventilation /Air Conditioning	
	Thank you for your help, Done TP				
55829	Complete	7/19/2017	Robert Taylor	Lounge	GATEWAY BUILDING
	Replace cartridge filters on espresso machines	8/24/2017 2:23:28	Taylor, Robert		
		Medium		Heating/Ventilation /Air Conditioning	
56613	Complete	9/11/2017	ASHLEE PATRICELLI	3rd Floor	GATEWAY BUILDING
	There is a small amount of water accumulating on the meeting table that looks as though it is dripping from the vent in the ceiling? Noone has used the conference room since Friday so it is not a spill or condensation.	9/13/2017 9:42:20	Hout, William		337
		Medium		Heating/Ventilation /Air Conditioning	
56692	Complete	9/15/2017	Joy Shain	4th Floor	GATEWAY BUILDING
	I need help with my properly operating my thermostat. Every day I come in and turn it down, and every night it resets to 76 degrees. When I come in every morning it feels about 80 and takes all day to cool down.	9/15/2017	Taylor, Robert		408D
		Medium		Heating/Ventilation /Air Conditioning	
57069	Complete	10/13/2017	KAREL MATHISEN	Office	GATEWAY BUILDING
	Please come and check and balance the temperature GW 403A. Even though it has a lot of windows, it is still quite a bit hotter than the ambient temperature outside (currently it is 78 in the office).	10/16/2017	Popilek, Thomas		GW403A
		Medium		Heating/Ventilation /Air Conditioning	
	Thank you. K. Mathisen (x. 2456), for C. Lorenzen				
	Previous office holder liked temps @ 73-77, I have adjusted temps to 67-71, Keep in mind windows are going to make it warmer as well and I cannot do much about that! TP				
57206	Complete	10/27/2017	Mary Lewallen	3rd Floor	GATEWAY BUILDING
	Please raise the room temperature in GW 345 to 70-72 degree range please. Thank you !!!!!	10/27/2017	Taylor, Robert		345
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
57311	Complete	11/7/2017	Becky Smith	3rd Floor	GATEWAY BUILDING
	Please raise the set point on my thermostat by 2 degrees. It is cold in here.	11/7/2017	Popilek, Thomas		303b
	Done! TP	Medium		Heating/Ventilation /Air Conditioning	
57625	Complete	12/11/2017		Office	GATEWAY BUILDING
	NOISE IN CEILING BETWEEN THE TWO LIGHTS AND IS INCREASING WITH FREQUENCY NOT SURE IF BALLAST OR SOMETHING ELSE - KATHY NOTTINGHAM	12/12/2017	Popilek, Thomas		303E
	Actuator was loose. TP	Medium		Heating/Ventilation /Air Conditioning	
57833	Complete	1/10/2018	Becky Smith	3rd Floor	GATEWAY BUILDING
	Could you please raise the set point in Jeanine's office? 2 degrees should hopefully do it.	1/10/2018	Popilek, Thomas		303C
		Medium		Heating/Ventilation /Air Conditioning	
57862	Complete	1/11/2018	Becky Smith	3rd Floor	GATEWAY BUILDING
	Could you please increase Katie McMillan's set point by 3 degrees? Thanks!	1/12/2018			309b
	Done TP	Medium		Heating/Ventilation /Air Conditioning	
58101	Complete	1/31/2018	Rebekah Wise	3rd Floor	GATEWAY BUILDING
	The A/C in Denise's office comes on mid-day. She's unable to keep the room warm	2/23/2018	Popilek, Thomas		306B
	I was asked on 10-12-17 to set temps to 64 heat-72 cool TP. "NEED TO KNOW TEMPS TO ADJUST" T STAT was adjusted to desired temp. TP	Medium		Heating/Ventilation /Air Conditioning	
58282	Void	2/20/2018	Patti Rohrbeck	4th Floor	GATEWAY BUILDING
	Our thermostats are not working properly. The offices in Human Resources are very hot.	Medium		Heating/Ventilation /Air Conditioning	402
	Tom Already fixed it				
58390	Complete	2/28/2018	Becky Smith	3rd Floor	GATEWAY BUILDING
	Tina Silva would like the setpoint in her office increased by 2 degrees. Thanks!	2/28/2018			307
		Medium		Heating/Ventilation /Air Conditioning	
58483	Complete	3/9/2018	Becky Smith	3rd Floor	GATEWAY BUILDING
	Please lower set point to 71.	3/9/2018 9:56:49	Taylor, Robert		303b
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
59886	Complete	8/10/2018	ASHLEE PATRICELLI	3rd Floor	GATEWAY BUILDING
	Maria Conner in GW 339 would like the temperature increased. She would like the room at about 72 degrees. Thank you CALLED AND SET TEMP, EXPLAINED HOW SYSTEM WORKS WITH 4 DEGREE HEAT/COOL TP	8/13/2018	Popilek, Thomas	Heating/Ventilation /Air Conditioning	339
59984	Complete	8/17/2018	Robert Taylor	Roof	GATEWAY BUILDING
	AHU malfunctioning	8/24/2018	Taylor, Robert	Heating/Ventilation /Air Conditioning	
60463	Complete	9/18/2018	Valerie Sailer	Board/Conference Room	GATEWAY BUILDING
	September 27-28, Thursday-Friday 6 am - 9 am Turn thermostat down to 68 degrees. Wyoming Health Fair Melissa Huggert 307.315.2824 GW 225	9/28/2018 7:19:28	Taylor, Robert	Heating/Ventilation /Air Conditioning	GW 225
61107	Complete	11/19/2018	Becky Smith	3rd Floor	GATEWAY BUILDING
	Could you please increase the set point on the thermostat in Jody's office by 2 degrees? RAISED 2	11/20/2018	Popilek, Thomas	Heating/Ventilation /Air Conditioning	303C
61179	Complete	11/29/2018	Patti Rohrbeck	4th Floor	GATEWAY BUILDING
	Please set the thermostat in Jenn Pepples office to 75 in 402A and Angel Race's thermostat to 74 in 402C SET TO 74 AND 75 TP	11/29/2018	Popilek, Thomas	Heating/Ventilation /Air Conditioning	402C, 402A
61422	Complete	1/4/2019	Robert Taylor	3rd Floor	GATEWAY BUILDING
	Replace leaking valve and actuator	1/8/2019 6:05:27	Taylor, Robert	Heating/Ventilation /Air Conditioning	341
61766	Complete	2/4/2019	CORY GARVIN	4th Floor	GATEWAY BUILDING
	Hello, is there a way to turn up my set point in GW403B? I believe it's set at 69 degrees right now and I'm having to turn it up every morning. Thank you! Turned up to 70	2/5/2019	Popilek, Thomas	Heating/Ventilation /Air Conditioning	403B

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
62180	Complete	3/14/2019	Patti Rohrbeck	4th Floor	GATEWAY BUILDING
	Please adjust the thermostat to 71 degrees. It is currently 74 degrees	3/14/2019 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	402
62465	Complete	4/9/2019	Jennifer Stedillie	4th Floor	GATEWAY BUILDING
	We actually don't know what this is. Could be the lights. We don't know' The problem: There is a very loud sound in the hallway right across from room 408C. The Dean and Staff Members are having a hard time around this sound because it is loud and we aren't sure if it is indicative of a larger problem. Thank you for your help with this. It is a light fixture vibrating from the Air Handler.	4/11/2019 6:47:14 Medium	ST.JOHN, TOM	Heating/Ventilation /Air Conditioning	hallway (408C)
63123	Complete	6/11/2019	Robert Taylor	Boiler Room	GATEWAY BUILDING
	Replace LWCO modules and probes	6/20/2019 6:41:57 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	
63318	Complete	7/3/2019	Robert Taylor	Roof	GATEWAY BUILDING
	Johnson Controls to look at AHU. Condenser fan not cycling.	8/14/2019 6:47:02 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	
63351	Complete	7/8/2019	Kortni Simonton	3rd Floor	GATEWAY BUILDING
	Can you please raise the Thermostat Range in Jana's office to be warmer. RAISED SET POINT FROM 68 HEAT to 70 AND COOLING FROM 72 TO 74	7/17/2019 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	339
63479	Duplicate Request	7/18/2019		Boiler Room	GATEWAY BUILDING
	REPLACE CONDENSATION DRAINS TO BOILERS - PATRICK PERRY SAME AS W.O. 63054	Medium	Perry, Patrick	Heating/Ventilation /Air Conditioning	110

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
63573	Complete	7/29/2019		2nd Floor	GATEWAY BUILDING
	Hello, I spoke with Tom Popilek at the beginning of 2019. He let us know there would be a vent cut for the freezer in the Gateway kitchen. There is not proper circulation so the freezer always gets overly iced up. Please let me know what the status of the project is or how to move forward. If possible, we would still like the vent cut to allow for proper air flow. Thank you. WE NEEDED THIS W.O. ORDER, THANK YOU FOR THIS. Cut in hole for vent. Installed cover and cleaned up mess.	7/29/2019 2:32:04 Medium	Harris, Nathan	Heating/Ventilation /Air Conditioning	224
63601	Complete	7/31/2019		Room	GATEWAY BUILDING
	WYOMING HEALTH FAIRS WILL NEED THE ROOM TEMPS LEFT AT 68 DEGREES WHILE PEOPLE ARE IN THERE STARTING SEPT 25 FROM 2 - 5 PM THE 26TH & 27TH FROM 5 AM UNTIL NOON EACH DAY -	9/30/2019 5:19:06 Medium	Taylor, Robert	Heating/Ventilation /Air Conditioning	225
64082	Complete	9/4/2019	Kortni Simonton	3rd Floor	GATEWAY BUILDING
	Could you please close the Air Conditioner vent in office 339. The thermostat range has been previously raised but the temperature in the room will not reach the max temperature of the thermostat range. THE AIR IS OFF	9/5/2019 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	339
64453	Complete	10/7/2019		Building	GATEWAY BUILDING
	AIR SAMPLING/TESTING - ERIC	10/30/2019 Medium	Cook, Lynnea	Heating/Ventilation /Air Conditioning	000
64626	Complete	10/22/2019	Jennifer Stedillie	4th Floor	GATEWAY BUILDING
	Laura Driscoll requested that this issue be looked into again. There is a very loud sound happening in the 408 hallway. Back in April it was determined that "It is a light fixture vibrating from the Air Handler." Thank you for your help. INSTALLED REGISTERS TO SEE IF THAT HELPS. TP	11/7/2019 Medium	Popilek, Thomas	Heating/Ventilation /Air Conditioning	GW 408

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
64724	Complete	10/30/2019	Christopher Lorenzen	4th Floor	GATEWAY BUILDING
	Temperatures in the office are between 77 and 82 degrees this afternoon. Manually lowering the temperature didn't effect the temperature nor did opening the front door to the office to circulate with the rest of the building.	10/31/2019	Popilek, Thomas		403
	PLEASE UNDERSTAND THAT DUE TO LOW TEMPS THE AIR HANDLER WILL NOT GO INTO COOLING, WITH AMAJORITY OF THE BUILDING NEEDING HEAT. THE UNIT GIVES AN AVERAGE OF 67 DEGREE AIR TO THE BUILDING. WITH THE SUN IN THE AFTERNOON AND AMOUNT OF WINDOWS YOU GET PASSIVE HEAT. THEREFORE YOUR AREA WILL OVER HEAT TO WHICH THERE IS NO REAL CONTROL. I WOULD SUGGEST CLOSING BLINDS OR ADDING A DARKER SHADE. POSSIBLY USING FANS AS WELL? TP	Medium		Heating/Ventilation /Air Conditioning	
64811	Complete	11/7/2019	Keri Owen	4th Floor	GATEWAY BUILDING
	Vent in 408D has a new rattle when the air is on; just started this week.	11/13/2019	Taylor, Robert		408D
	Re-attached loose VAV controller	Medium		Heating/Ventilation /Air Conditioning	
65606	Complete	2/5/2020	Kortni Simonton	3rd Floor	GATEWAY BUILDING
	Will you raise the thermostat range in Samantha Smith's office GW 337	2/10/2020	Popilek, Thomas		337
	raised temp range	Medium		Heating/Ventilation /Air Conditioning	
66789	Complete	6/23/2020		Entrance	GATEWAY BUILDING
	1ST FLOOR ENTRYWAY HAS A HEATER STILL RUNNING - LISA ICENOGLE	6/24/2020	Taylor, Robert		100
	TURNED OFF. TP	Medium		Heating/Ventilation /Air Conditioning	
66808	Work In Progress	6/23/2020	Shane Pulliam		GATEWAY BUILDING
	Can we please get an air deflector put on Debbie's air vent.		Popilek, Thomas		311
		Medium		Heating/Ventilation /Air Conditioning	
67042	Complete	7/20/2020	Erik Christensen	Office	GATEWAY BUILDING
	Please reset the thermostat in GW 408F for a range of 68-72. Thank you.	7/21/2020	Popilek, Thomas		408F
		Medium		Heating/Ventilation /Air Conditioning	

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority		Craft	Equipment
67054	Complete	7/21/2020	Robert Taylor	Roof	GATEWAY BUILDING
	Replace compressor 8 contactors	7/30/2020 4:55:17	Taylor, Robert		
		Medium		Heating/Ventilation /Air Conditioning	
67306	Complete	8/6/2020	Shane Pulliam	3rd Floor	GATEWAY BUILDING
	Can I please have my thermostat set point lowered to 67 degrees or as low as I can get it?	8/6/2020	Popilek, Thomas		311
	Lowered	Medium		Heating/Ventilation /Air Conditioning	
67759	Complete	9/8/2020	Shane Pulliam	3rd Floor	GATEWAY BUILDING
	Can I please have my thermostat changed so that 70 degrees is the middle point?	9/9/2020	Popilek, Thomas		311
	70 is mid point as requested. tp	Medium		Heating/Ventilation /Air Conditioning	