

Addendum #1

RFP #CC616-26

2026 ASPHALT HABILITATION

Questions and Answers:

1. Note 2 on sheet 2 of the plans call for Macro Fiber reinforcement in all concrete. Concrete details on sheets 14 and 15 show polypropylene fibers for valley gutter and no fiber is called out for the curb and gutter details. Is the macro fiber intended to be used in Valley Gutters and Curb and Gutter or only in the concrete pavement sections?
 - Fiber is not required for curb and gutter. Pavement and valley pan shall have fiber.
2. Section 2 instructions to bidders #10 B has Wy prevailing wage as applying to this project. Is that correct? If yes please provide the wage rates as required in W.S. 27-4-405.
 - Please see this URL with the prevailing wage tables https://www.dot.state.wy.us/home/engineering_technical_programs/prevailing_wage.html
3. Is a bid Bond required on this project?
 - No
4. Are round manhole and valve box collars acceptable if installed per the new City of Casper specifications?
 - Casper College would prefer to have all square collars to keep it standardized across our campus.



Shane Pulliam
Director of Procurement

shane.pulliam@caspercollege.edu

Ph: 307-268-2633

Fax: 307-268-2880